

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7272-1496:173

Page 1 of 1

CATEGORY: Photoelectric Smoke Detector

LISTEE: Firecom, Inc., 39-27 59th Street, Woodside, NY 11377
Contact: Howard Kogen (718) 899-6100 FAX (718) 899-1932

DESIGN: Series XP95A Model F900-886 photoelectric type smoke detector. Unit employs an integral supplemental heat sensor. This heat sensor is intended for use as a supplemental device to the smoke detector and is not intended for use in lieu of required heat detectors. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as a photoelectric smoke detector for use with separately listed compatible fire alarm control units and listee's separately listed Models F900-MB-6 or F900-MB-6LP (CSFM Listing No. 7300-1496:128) detector mounting bases. Refer to listee's Installation Instruction Manual for details.

NOTE: The photoelectric type detectors are generally more effective at detecting slow, smoldering fires that smolder for hours before bursting into flames. Sources of these fires may include cigarettes burning in couches or bedding. The ionization type detectors are generally more effective at detecting fast, flaming fires that consume combustible materials rapidly and spread quickly. Sources of these fires may include paper burning in a waste container or a grease fire in the kitchen.

XLF: 7272-1394:113

05-26-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 23, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**